



NOTES

1. PIPE SHALL BE 3" DIA PVC PLASTIC PIPE (SCH 40).
2. WIRE MESH SHALL BE 3 X 3 10 GAUGE.
3. CEMENT CONCRETE SHALL BE CLASS B (3/4").
4. REINFORCING BAR SHALL BE #3 (3/8" DEFORMED BAR
5. SIDEWALK AND CURBING MUST BE SAW-CUT AT A DUMMY JOINT OR REMOVED TO A FULL EXPANSION JOINT.
6. SIDEWALK THICKNESS OF 4" MINIMUM.
7. FULL DEPTH OF CURB AND GUTTER MUST BE REMOVED AND REPLACED.

CITY OF KIRKLAND

PLAN NO. CK-D.19



RESIDENTIAL
SIDEWALK DRAIN