



NOTES

1. REQUIRED FOR ANY PIPE 12" OR LARGER.
2. ALL STEEL PARTS MUST BE GALVANIZED AND ASPHALT COATED (TREATMENT 1 OR BETTER).
3. DEBRIS BARRIER NOT ALLOWED ON OUTLET END.

CITY OF KIRKLAND

PLAN NO. CK-D.38A



TYPICAL DEBRIS
BARRIER FOR
DETENTION PONDS