



NOTES

1. TRENCH BACKFILL BELOW TOP 4 FEET MAY BE NATIVE MATERIALS OR AS REQUIRED BY THE SPECIFICATIONS, OR AS DIRECTED BY THE PUBLIC WORKS INSPECTOR.
2. MINIMUM TRENCH WIDTH SHALL BE PIPE ID + 24".
3. IN PAVED AREAS USE CRUSHED ROCK BACKFILL
 - * FULL DEPTH OF TRENCH WHERE SEWER MAIN CROSSES PERPENDICULAR TO THE TRAVELED LANE OR DRIVEWAY.
 - * TOP FOUR FEET WHERE SEWER MAIN RUNS PARALLEL TO THE TRAVELED LANE, UNLESS EXISTING MATERIAL IS DETERMINED BY THE ENGINEER TO BE SUITABLE FOR BACKFILL.
4. THE STREET SHALL BE OVERLAID WHEN THE ASPHALT ROADWAY IS LESS THAN 5YRS OLD FOR UTILITY CROSSINGS, THE STREET SHALL BE OVERLAID AT LEAST 25 FEET ON EACH SIDE OF THE TRENCH. SEE OVERLAY POLICY R-7.

CITY OF KIRKLAND	
PLAN NO. CK-S.01	
	SANITARY SEWER TRENCH DETAIL