



**NOTES**

1. ALL PVC FITTINGS SHALL BE GASKETED.
2. NO COLLECTION VALVE BOX REQUIRED.
3. CAP MAY BE BURIED 18" BELOW GRADE WITH PVC CAP, IF NOT PLACED UNDER HARD SURFACES.
4. FOR 1-1/4" SERVICE USE 2"x1-1/4" BRASS BUSHING FOR 2" TAP.
5. FOR 2" SERVICE, OMIT BUSHING.

<b>CITY OF KIRKLAND</b>	
PLAN NO. CK-S.28A	
	<b>SHALLOW FORCE MAIN CONNECTION</b>