



NOTES

1. REQUIRED FOR ANY PIPE 8" OR LARGER.
2. DEBRIS BARRIER MUST BE ALL ALUMINUM.
3. DEBRIS BARRIER NOT ALLOWED ON OUTLET END.
4. ALL BOLT HARDWARE SHALL BE STAINLESS STEEL.

CITY OF KIRKLAND	
PLAN NO. CK-D.38A	
	<p style="text-align: center; font-weight: bold;">TYPICAL DEBRIS BARRIER FOR DETENTION PONDS</p>