



**Kirkland Avenue Water and Sewer Replacement**

**CIP No. CWA-0133**

**CIP No. CSS-0072**

**Job No. 48-18-PW**

**Addendum No. 3**


Addendum Issue Date: January 25, 2019

Bid Opening: Wednesday, January 30, 2019 at 2:00 pm  
City of Kirkland  
City Hall  
123 5<sup>th</sup> Avenue  
Kirkland, WA 98033

Notice to All Plan Holders:

This Addendum No. 3, containing the following revisions, addition, and/or clarification, is hereby made part of the Contract Documents for the above-named project. Bidders shall take this Addendum into consideration when preparing and submitting their bids and it shall be attached to the Contract Documents.

Bidders shall acknowledge receipt of this Addendum No. 3 in the place provided on the Proposal – Page 7 of the revised bid proposal forms. Failure to do so may disqualify the Bidder from consideration of their bid.



Ref	Section and Page or Drawing	Description of Change
<b>CLARIFICATIONS</b>		
<b>SPECIFICATIONS</b>		
<b>DRAWINGS</b>		
3.1	Sheet 9, as revised per Addendum #1	<p><b>Replace</b> Construction Note 5 in its entirety with the following:</p> <p>Side sewer shall be C-900 pipe with fittings meeting AWWA Standard C110/C153. Transition to SDR-35 pipe at the cleanout wye.</p>
3.2	Sheet 10, as revised per Addendum #1	<p><b>Replace</b> Construction Note 2 in its entirety with the following:</p> <p>Side sewer shall be C-900 pipe with fittings meeting AWWA Standard C110/C153. Transition to SDR-35 pipe at the cleanout wye.</p>
3.3	Sheet 11, as revised per Addendum #1	<p><b>Replace</b> Construction Note 4 in its entirety with the following:</p> <p>Side sewer shall be C-900 pipe with fittings meeting AWWA Standard C110/C153. Transition to SDR-35 pipe at the cleanout wye.</p>