



**NOTES**

1. ALL HOUSE DOWNSPOUTS AND EXTERIOR SURFACE DRAINS MUST BE CONNECTED TO THE PUBLIC DRAIN SYSTEM, DETENTION FACILITY OR LID BMP (IF APPLICABLE). NO STORM DRAINAGE MAY BE CONNECTED TO PUBLIC SANITARY SEWER SYSTEM.
2. MINIMUM GRADE 2 % FOR 6" AND 2 % FOR 4", AND 1% FOR 8".
3. ALL CONSTRUCTION WITHIN STREETS AND/OR PUBLIC RIGHT-OF-WAYS MUST BE DONE BY A GENERAL CONTRACTOR LICENSED BY THE STATE AND COK.
4. NEW TIE-INS NOT IN THE VICINITY OF A CATCH BASIN MAY SADDLE THE STORM MAIN IF A 6" LINE IS EXTENDED AND A YARD DRAIN IS PLACED WITHIN 10' OF PROPERTY LINE.
5. BACKFILL MATERIAL IN THE RIGHT-OF-WAY AND UNDER PAVED SURFACES SHALL BE 5/8" MINUS COMPACTED TO 95 % OR GREATER (CRUSHED SURFACING TOP COURSE PER WSDOT 9-03.9(3)).
6. CLEANOUTS REQUIRED FOR EACH PIPE LENGTH GREATER THAN 100' AND FOR EACH ACCUMULATED 90 DEGREES PER 100'.

<b>CITY OF KIRKLAND</b>	
PLAN NO. CK- D.20	
	<b>LOT DRAIN CONNECTIONS</b>