



Fire and Life Safety Self-Inspection Checklist.

Be prepared before your annual inspection. Below are the most common fire code violations and the corresponding International Fire Code reference number, as adopted by the City of Kirkland.

RESTAURANTS

Restaurants with seating over 50 are also required to meet assembly occupancy requirements.

1. Grease accumulation on filters and/or in ducts (904.11 & 609.3.3.2)
2. Cooking Hood system not serviced, nonexistent (609.3, 904.11 & 904.11.6.1)
3. Decorations, curtains, draperies shall be fire retardant treated (807 and NFPA 701)
4. Fire extinguisher not serviced or nonexistent (901.6, 906.2 and NFPA 10)
5. Combustible materials shall not be stored in boiler rooms, mechanical rooms, or electrical equipment rooms (315.3.3)
6. Extension cords used as permanent wiring. (605.1, 605.4 and 605.5)
7. Lack of exit signs or exit sign lighting not working (1011.1)
8. Draperies shall not be placed over exit doors (1030.6)
9. Tables in exit paths (1003.6, 1030 and 1104.22)
10. Illegal locks on egress doors (1008.1.9.3.1 & 1008.1.10)
11. Emergency lighting missing or not tested (1006.1, 1006.3, 1104.4 and 1104.5)
12. Storage in exit path or tables blocking exit door (1003.6, 1030 and 1104.22)
13. No Occupant Load signs posted (1004.3 and 107.5)
14. Seating exceeds the posted Occupant Load signs (107.5)
15. Painted sprinkler heads (901.6 and NFPA 13-6.2.6.2.2)



Kirkland Fire Marshal

123 5th Ave
Kirkland, WA 98033
Phone: (425) 587-3650