

DRAFT Transition Plan

City of Kirkland



City of Kirkland ADA Compliance Plan

Contents

- Introduction 3
- Transition Plan 3
 - Facilities 5
 - Recreation Facilities 7
 - Curb Ramps 7
 - Website 7

Transition Plan

Introduction

The Americans with Disabilities Act (ADA) requires all public services, policies and practices to be compliant as outlined in Title II. The City of Kirkland has established a Pathway to Transition document that summarizes the Title II ADA compliance requirements, outlines the actions needed to meet those requirements and contains assessment results. For those services, programs and activities that were identified as not being in compliance, the City is required to prepare a Transition Plan for structural improvements, as well as correct deficiencies for those services, programs and activities that are not a structural improvements. The Transition Plan illustrates how and when the City plans to correct identified deficiencies. The Transition Plan, in draft format, will be posted on the City's website (www.kirklandwa.gov) for public review and comments. The Transition Plan is a living document, which will be updated annually.

Below is the definition of a Transition Plan from the Americans with Disabilities Act Title II Regulations Part 35- Nondiscrimination on the Basis of Disability in State and Local Government Services.

Transition Plan

If a public entity has responsibility or authority over streets, roads, or walkways, its transition plan shall include a schedule for providing curb ramps or other sloped areas where pedestrians walks cross curbs, giving priority to walkways serving entities covered by the ACT, including State and local government offices and facilities, transportation, places of public accommodation, and employers, followed by walkways serving other areas.

The plan shall, at a minimum –

- *Identify physical obstacles in the public entity's facilities that limit the accessibility of its programs or activities to individuals with disabilities*
- *Describe in detail the methods that will be used to make the facilities accessible*

- *Specify the schedule for taking the steps necessary to achieve compliance with this section and, if the time period of the transition plan is longer than one year, identify steps that will be taken during each year of the transition period*
- *Indicate the official responsible for implementation of the plan (Title II ADA 35.150)*

The Transition Plan lists each area needing correction along with costs, methods/steps to make them accessible, correction schedule and responsible party. As areas are brought into compliance, items will move out of the Transition Plan and the corrections recorded in the Pathway to Transition document.

Facilities

The City of Kirkland completed an assessment of all City Facilities in 2014. This assessment was completed by Facilities maintenance staff using criteria using criteria for accessible pathways, building access and parking.

Overall Facility ADA Corrections with budget and timeline

Facilities								
Facilities		2014						
Tran Plan Code	Facility	Status	BARRIER: Building Access	BARRIER: Building Corridors	BARRIER: Restrooms	BARRIER: Personnel Office	Project Cost	Estimated Completion Date
F13	Fire Station 22	Non-Compliant	Non-Compliant	Non-Compliant	Compliant	Compliant	\$ 7,000,000	2020
F14	Fire Station 24	Non-Compliant	Non-Compliant	Non-Compliant	Non-Compliant	Non-Compliant	To be Sold	2019
F15	Fire Station 25	Non-Compliant	Compliant	Non-Compliant	Non-Compliant	Compliant	\$ 3,700,000	2019
F16	Fire Station 26	Non-Compliant	Non-Compliant	Non-Compliant	Compliant	Compliant	\$ 8,100,000	2020
F17	Fire Station 27	Non-Compliant	Non-Compliant	Non-Compliant	Non-Compliant	Compliant	\$ 2,000,000	2020

Building Access Corrections

Facilities											
Facilities		2014									
Tran Plan Code	Facility	Status	BARRIER: Building Access	Are 96" wide parking spaces designated with 60" aisle	Are parking spaces near main building entrance?	Is there a "drop off" zone at building entrance?	Is the gradient from parking to building entrance 1:12 or less?	Is the entrance dorrway to least 32 inches wide?	Is door easy to open (less than 8lbs. Pressure)?	Are other than revolving doors available?	
F13	Fire Station 22	Non-Compliant	Non-Compliant	No	Yes	No	No	Yes	Yes	Yes	
F14	Fire Station 24	Non-Compliant	Non-Compliant	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	
F15	Fire Station 25	Non-Compliant	Compliant	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
F16	Fire Station 26	Non-Compliant	Non-Compliant	Yes	Yes	No	No	Yes	Yes	Yes	
F17	Fire Station 27	Non-Compliant	Non-Compliant	Yes	Yes	Yes	Yes	No	No	Yes	

Building Corridor Corrections

Facilities										
Facilities		2014								
Tran Plan Code	Facility	Status	BARRIER: Building Corridors	Is path of travel free of obstruction and wide enough for a wheelchair?	Is floor surface firm, level and not slippery?	Do obstacles (phone, fountains) protrude no more than 4 inches?	Are the elevator controls low enough (54") to be reached from a wheelchair?	Are elevator markings in Braille and raised letters for the blind?	Does elevator provide audible signals for the blind?	Does elevator interior provide a turning area of 51" for a wheelchair?
F13	Fire Station 22	Non-Compliant	Non-Compliant	Yes	Yes	No	N/A	N/A	N/A	N/A
F14	Fire Station 24	Non-Compliant	Non-Compliant	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess
F15	Fire Station 25	Non-Compliant	Non-Compliant	Yes	Yes	No	N/A	N/A	N/A	N/A
F16	Fire Station 26	Non-Compliant	Non-Compliant	Yes	Yes	No	Yes	No	No	Yes
F17	Fire Station 27	Non-Compliant	Non-Compliant	Yes	Yes	No	N/A	N/A	N/A	N/A

Restroom Corrections

Facilities												
Facilities			2014									
Tran Plan Code	Facility	Status	BARRIER: Restrooms	Are restrooms near building entrance/personnel?	Do doors have level handle?	Are doors at least 32" wide?	Is restroom large enough for wheelchair turnaround (60" minimum)?	Are stall doors at least 32" wide?	Are grab bars provided in toilet stalls?	Are sinks and counters at least 36" high with room for a wheelchair to roll under?	Are sink handles easily reached and used?	Are soap dispensers, towels no more than 48" from floor?
F13	Fire Station 22	Non-Compliant	Compliant	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
F14	Fire Station 24	Non-Compliant	Non-Compliant	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess	Re-Assess
F15	Fire Station 25	Non-Compliant	Non-Compliant	Yes	No	Yes	Yes	Yes	No	No	No	No
F16	Fire Station 26	Non-Compliant	Compliant	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
F17	Fire Station 27	Non-Compliant	Non-Compliant	Yes	No	No	No	No	No	No	No	Yes

Personnel Office Corrections

Facilities												
Facilities			2014									
Tran Plan Code	Facility	Status	BARRIER: Personnel Office	Are doors at least 32" wide?	Is the door easy to open?	Is the threshold no more than 1/2" high?	Is the path of travel between desks, tables wide enough for wheelchairs?	Project Cost	Estimated Completion Date			
F13	Fire Station 22	Non-Compliant	Compliant	Yes	Yes	Yes	Yes	\$ 7,000,000	2020			
F14	Fire Station 24	Non-Compliant	Non-Compliant	Re-Assess	Re-Assess	Re-Assess	Re-Assess	To be Sold	2019			
F15	Fire Station 25	Non-Compliant	Compliant	Yes	Yes	Yes	Yes	\$ 3,700,000	2019			
F16	Fire Station 26	Non-Compliant	Compliant	Yes	Yes	Yes	Yes	\$ 8,100,000	2020			
F17	Fire Station 27	Non-Compliant	Compliant	Yes	Yes	Yes	Yes	\$ 2,000,000	2020			

Recreation Facilities

Recreation Facilities were included in the 2014 Facilities Assessment. Parks facilities were assessed using criteria for accessible pathways, building access and parking.

Recreation Facilities

City Parks

Tran PI Co	Park Name	Complianc Y	Neighborn Y	Accessible Walks	Accessible Trail	Accessible Play Structure	Access to Facilities (all other re specific)	Restr Y	Stac Y	Athletic Fit	Accessible Parkin	Cost	Planned Date	Responsible Part	Accessible Projects (started for 2019-2)	Completion Date	Besim Prio	Project Le	Planned Date				
P5	Brookhaven	Not ADA Accessible	North Juanita	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	\$ 150,000	2021	Parks Dept.	Accessible pathway to cross		R2		2019- 2021				
P7	Canlon Woods	Not fully ADA Accessible	Central Houghton	No	No	Yes	No	N/A	N/A	N/A	Yes	\$ 500,000	2021	Parks Dept.	ADD ADA accessible connections to existing amenities, Upgrade play structures and facilities.		R2		2019- 2021				
P8	Cedar View Park	Not fully ADA Accessible	Highlands	No	N/A	No	Yes	N/A	N/A	N/A	Yes	\$ 150,000	2021	Parks Dept.	Accessible paths, ADA accessible swing		R2		2019- 2021				
P10	Crestwoods Park	Not fully ADA Accessible	Worrick	Yes	No	No	Yes	Yes	N/A	No	Yes	\$ 1,100,000	2030	Parks Dept.	Upgrade play structure to ADA compliance, access to sports fields/facilities		R2		2019- 2021				
P20	Highlands	Not ADA Accessible	Highlands	No	N/A	No	No	N/A	N/A	No	N/A	\$ 500,000	2021	Parks Dept.	Accessible ramps to play area, Upgrade picnic table to ADA compliant and		R2		2019- 2021				
P22	Jasper's Dog Park	Not fully ADA Accessible	Totem Lake	No	No	N/A	Yes	N/A	N/A	N/A	Yes	\$ 250,000	2021	Parks Dept.	Accessible pathway from parking to dog park		R2		2019- 2021				
P25	Juanita Beach Park	Not fully ADA Accessible	South Juanita	Yes	Yes	Yes	Yes	No	N/A	Yes	Yes	\$ 1,200,000	2019	Parks Dept.	Benches replacement and shelter		R2	2 years	2017-2018				
P33	Mark Twain	Not ADA Accessible	North Rose Hill	No	No	No	N/A	N/A	N/A	N/A	N/A	\$ 400,000	2021	Parks Dept.	Accessible ramps to play area		R2		2019- 2021				
P35	McAuliffe Park	Not ADA Accessible	South Juanita	No	No	No	No	No	N/A	N/A	Yes	\$ 400,000	2021	Parks Dept.	ADA accessible planting beds and pathways		R2		2019- 2021				
P37	North Kirkland Community Center	Not fully ADA Accessible	North Juanita	Yes	No	Yes	Yes	Yes	N/A	N/A	Yes	\$ 200,000	2021	Parks Dept.	Access-Gully to front of the building		R2		2019-2021				
P42	Phyllis A Neady	Not ADA Accessible	Central Houghton	No	N/A	No	No	Yes	N/A	N/A	N/A	\$ 100,000	2021	Parks Dept.	Accessible paths, Upgrade picnic table to ADA compliant		R2		2019-2021				
P43	Reservoir	Not fully ADA Accessible	Worrick	Yes	N/A	No	N/A	N/A	N/A	N/A	N/A	\$ 100,000	N/A	N/A	New play structure	?			2021-2022				
P44	Rose Hill Meadows	Not fully ADA Accessible	South Rose Hill	Yes	Yes	Yes	No	N/A	Yes	N/A	N/A	\$ 200,000	2021	Parks Dept.	Adaptive Swing, Upgrade picnic table to ADA compliant		R2		2019-2021				
P48	South Rose Hill	Not fully ADA Accessible	South Rose Hill	No	Yes	Yes	Yes	Yes	N/A	N/A	N/A	\$ 200,000	2021	Parks Dept.	Accessible ramps to play area, Upgrade picnic table to ADA compliant		R2		2019-2021				
P49	Spinney Homestead	Not fully ADA Accessible	Highlands	No	No	No	Yes	N/A	N/A	N/A	Yes	\$ 120,000	2019	Parks Dept.	Accessible ramps to play area		R2		2019-2021				
P52	Terrace Park	Not fully ADA Accessible	South Rose Hill	No	N/A	No	No	N/A	N/A	N/A	Yes	\$ 100,000	2019	Parks Dept.	Accessible ramps to play area		R2		2019-2021				
P55	Van Aalst	Not ADA Accessible	Worrick	No	N/A	No	No	N/A	N/A	N/A	N/A	\$ 200,000	2021	Parks Dept.	Accessible ramps to play area		R2		2019-2021				
P56	Watershed Park	Not ADA Accessible	Central Houghton	N/A	No	N/A	N/A	N/A	N/A	N/A	N/A	\$ 1,200,000	2021	Parks Dept.	ADA accessible path		R2		2019-2021				
P58	Windsor Vista	Not fully ADA Accessible	North Juanita	N/A	No	N/A	N/A	N/A	N/A	N/A	N/A	\$ 700,000	2021	Parks Dept.	Porous pathway with ADA accessibility, Bridge		R2		2019-2021				
												Total	\$13,630,000										

Curb Ramps

The Public Works department has proposed to address corrections to 80 curb ramps per year through 2058 at a total estimated cost of \$14.8 million dollars. These repairs will come through overlay projects, capital improvement projects and development. The locations will be assigned as projects are identified.

Website

The Information Technology department completed a strategic plan in 2018. This strategic plan allocates \$200,000 in 2019 to provide funding for a city website replacement where ADA compliancy is a primary requirement.