


NOTES:

1. ELBOWS SHALL NOT BE GREATER THAN 45 DEGREES.
2. CLEAN OUT IS REQUIRED FOR EACH PIPE LENGTH GREATER THAN 100' AND FOR EACH 90 DEGREES ACCUMULATED ELBOW PER 100'.
3. RIGHT-OF-WAY RESTORATION SHALL MATCH OR EXCEED THE ORIGINAL CONDITION AND BE IN ACCORDANCE WITH THE CITY STANDARD.
4. BACKFILL FOR PAVED AREA SHALL BE 3/4" MINUS CRUSHED SURFACING TOP COURSE, COMPACTED IN 12" LIFTS.
5. ALL HOUSE PLUMBING OUTLETS MUST BE CONNECTED TO THE SEWER. NO DOWNSPOUTS OR STORM DRAINAGE MAY BE CONNECTED TO THE SEWER SYSTEM.
6. 6' MINIMUM COVERAGE AT PROPERTY LINE.
7. LAY PIPE IN STRAIGHT LINE BETWEEN BENDS. MAKE ALL CHANGES IN GRADE OR LINE WITH A 1/8 BEND OR WYE. 90 DEGREE CHANGE WITH 1/8 BEND AND WYE.
8. 6" SEWER PIPE MINIMUM SIZE IN STREET, AND ELSEWHERE AS DIRECTED BY ENGINEER. 2% MINIMUM GRADE (UNLESS DIRECTED BY ENGINEER) 50% MAXIMUM.
9. 4" SEWER PIPE MINIMUM SIZE ON PROPERTY. 2% MINIMUM GRADE, 100% (45 DEGREE) MAXIMUM.
10. TEST "T" WITH PLUG AT WYE.
11. ALL CONSTRUCTION WITHIN STREETS AND/OR PUBLIC RIGHT-OF-WAYS MUST BE DONE BY A STATE LICENSED GENERAL CONTRACTOR.
12. ALL CONSTRUCTION SHALL BE IN ACCORDANCE WITH CURRENT SIDE SEWER ORDINANCES.
13. ALL CONSTRUCTION REQUIRES A PERMIT AND PAYMENT OF FEE, COMPLETE LEGAL DESCRIPTION OF PROPERTY AND DIMENSIONS.
14. BACKFLOW PREVENTER (CHECK VALVE) IS REQUIRED:
 - a) IF CONNECTED TO A JOINT USE SIDE SEWER.
 - b) IF CONNECTION AT HOUSE IS LOWER THAN UPSTREAM MANHOLE LID.
15. AS-BUILT DRAWING SHOWING LOCATION OF SIDE SEWER IN RELATION TO THE HOUSE IS REQUIRED AFTER INSTALLATION.
16. SIDE SEWER BEDDING: PEA GRAVEL.
17. ASTM D-3034 OR SDR-35.

| | |
|--|--|
| CITY OF KIRKLAND | |
| PLAN NO. CK- S.20 | |
|  | RESIDENTIAL SIDE SEWER INSTALLATION |