



ROCKERY HEIGHT (FT)	SIZE OF D	MIN ROCK SIZE (BASE)	MIN ROCK SIZE (TOP)
2	3 INCHES	2-MAN	1-MAN
4	6 INCHES	3-MAN	2-MAN
6	9 INCHES	4-MAN	2-MAN
8	12 INCHES	5-MAN	2-MAN

NOTES

1. ROCKERY MUST BE INSTALLED BY LICENSED ROCKERY CONTRACTOR.
2. IF ROCKERY HEIGHT EXCEEDS 4', IT MUST BE DESIGNED BY A PRACTICING GEOTECHNICAL/CIVIL ENGINEER LICENSED IN THE STATE OF WASHINGTON.
3. FILTER FABRIC SHALL BE MIRAFI 140 N SERIES OR APPROVED EQUAL.
4. APPROVED 6" PERF PVC DRAINLINE TIE TO PUBLIC STORM SYSTEM MUST BE INSPECTED BY PUBLIC WORKS.

CITY OF KIRKLAND

PLAN NO. CK-R.54

ROCKERY DETAIL
SIDEWALK SUPPORT