



PARALLEL CONSTRUCTION

TABLE 1

WATER MAIN STANDARD PIPE MATERIAL

AWWA STANDARD			
TYPE OF PIPE	PIPE	JOINT	FITTINGS
DUCTILE IRON	C 1.52	C 111	C 110
CONCRETE CYLINDER	C 303		

NOTE:

1. TO BE USED WHEN 10' MINIMUM SEPARATION CANNOT BE OBTAINED.

CITY OF KIRKLAND

PLAN NO. CK- S.02



**WATER AND SEWER
SPACING AND
CLEARANCE**