



**P-14938
POLYPROPYLENE STEP**



SPECIFICATIONS:


1. ALL STEPS SHALL MEET THE REQUIREMENTS OF ASTM C-478, AASHTO M-199, WISHA AND ALL ASHA SPECIFICATION.
2. THE POLYPROPYLENE SHALL CONFORM TO ASTM D-4101. ASTM D-4101.
3. THE 1/2" GRADE 60 DEFORMED REINFORCING BAR SHALL MEET ASTM A-615.
4. STEP REFLECTORS OR BRIGHT COLORED STEPS REQUIRED.



SECTION B-B

INSTALLATION:

1. THE STEP CAN BE CAST IN PLACE.
2. DRIVEN INTO PREFORMED HOLES WITH CONCRETE CURED TO 3,000 PSI MINIMUM.
3. DRIVEN INTO 2 PARALLEL 1" DIAMETER HOLES DRILLED 13" OR 10" ON CENTER, 3-1/2" DEEP.
4. DRILL 2 1-1/8" OR 1-1/4" HOLES, 3-1/2" DEEP, APPLY CURRENT WSDOT EPOXY SPECIFICATION IN THE HOLE AND AROUND THE BARBS OF THE STEP. PUSH THE STEP INTO THE HOLES ALLOWING THE EPOXY TO FLOW OUT TO THE SQUARE SHOULDER OF THE STEP.



SECTION C-C

ANY OF THE ABOVE METHODS WILL RESIST A PULLOUT FORCE OF OVER 1,500 LBS.

CITY OF KIRKLAND	
PLAN NO. CK-S.14	
	LADDER AND MANHOLE STEPS