


SECTION A-A

NOTES:

1. UTILITY VAULT COMPANY, INC., #25-SA, OR EQUAL. PRESET VAULT SHALL HAVE KNOCKOUTS AT ALL PIPE OPENINGS. IF KNOCKOUTS ARE NOT PRESENT THEN PIPE OPENINGS SHALL BE CORE-DRILLED. PIPE OPENINGS SHALL BE 2" LARGER THAN PIPE DIAMETER.
2. LOCATE WITHIN 20 FEET OF DRIVE FOR ACCESS BY MAINTENANCE VEHICLE.
3. INSPECTION AND SAMPLING TEE TO BE INSTALLED BY CONTRACTOR. LINE-SIZED PVC TEE SHALL BE USED WHERE LINE IS 6" DIA. OR GREATER. SIX INCH PVC TEE SHALL BE USED WHERE LINE-SIZE IS LESS THAN 6" DIA.
4. FILL WITH CLEAN WATER PRIOR TO STARTUP OF SYSTEM.
5. GRAY AND BLACK WATER SHALL BE CARRIED BY SEPARATE SIDE SEWER.
6. CONNECTIONS TO CONCRETE WALLS WITH P.V.C. PIPE REQUIRE KOR-N-SEAL CONNECTOR. SEAL ALL PIPE CONNECTIONS WITH NON-SHRINK GROUT.

CITY OF KIRKLAND	
PLAN NO. CK-S.23	
 <p>CITY OF KIRKLAND WASHINGTON</p>	<p>100 GALLON BAFFLE TYPE OIL/WATER SEPARATOR</p>