



PARALLEL CONSTRUCTION

TABLE 1
WATER MAIN STANDARD PIPE MATERIAL

AWWA STANDARD			
TYPE OF PIPE	PIPE	JOINT	FITTINGS
DUCTILE IRON	C 1.52	C 111	C 110
CONCRETE CYLINDER	C 303		

NOTES

1. TO BE USED WHEN 10' MINIMUM SEPARATION CANNOT BE OBTAINED.

CITY OF KIRKLAND	
PLAN NO. CK-W.01	
	WATER AND SEWER SPACING AND CLEARANCE