


EXTENSION DETAIL

NOTE:

1. VALVE EXTENSIONS ARE ONLY REQUIRED IF DEPTH FROM FINISHED GRADE TO TOP OF OPERATING NUT IS GREATER THAN 5 FEET.
2. WHEN AN EXTENSION IS USED, THE DEPTH FROM EXTENSION OPERATING NUT TO FINISHED GRADE SHALL NOT BE LESS THAN 3 FEET.

CITY OF KIRKLAND	
PLAN NO. CK-W.05	
	WATER VALVE EXTENSION