


NOTES

1. ALL HOUSE DOWNSPOUTS AND EXTERIOR SURFACE DRAINS MUST BE CONNECTED TO THE PUBLIC DRAIN SYSTEM, DETENTION FACILITY OR LID BMP (IF APPLICABLE). NO STORM DRAINAGE MAY BE CONNECTED TO PUBLIC SANITARY SEWER SYSTEM.
2. MINIMUM GRADE 2 % FOR 6" AND 2 % FOR 4", AND 1% FOR 8".
3. ALL CONSTRUCTION WITHIN STREETS AND/OR PUBLIC RIGHT-OF-WAYS MUST BE DONE BY A GENERAL CONTRACTOR LICENSED BY THE STATE AND COK.
4. NEW TIE-INS MUST INSTALL PVC/DI TEE OR INSERTA TEE FOR LATERAL CONNECTION. NO BREAK-IN CONNECTIONS WITH MORTAR ALLOWED. LATERAL PIPE MAY NOT PROTRUDE INTO MAINLINE.
5. BACKFILL MATERIAL IN THE RIGHT-OF-WAY AND UNDER PAVED SURFACES SHALL BE 5/8" MINUS COMPACTED TO 95 % OR GREATER (CRUSHED SURFACING TOP COURSE PER WSDOT 9-03.9(3)).
6. CLEANOUTS REQUIRED FOR EACH PIPE LENGTH GREATER THAN 100' AND FOR EACH ACCUMULATED 90 DEGREES PER 100'.

CITY OF KIRKLAND	
PLAN NO. CK - D.20	
	LOT DRAIN CONNECTIONS