


SIDE VIEW
NTS

RAIN GARDEN SHAPES WILL VARY.
SHAPE AND PLANTS SHOWN IN DIAGRAM
ARE FOR ILLUSTRATION PURPOSES ONLY.



PLAN VIEW
NTS

PLANTING ZONES

- ZONE 1: AREA WITH FREQUENT STANDING WATER.
- ZONE 2: AREA WITH OCCASIONAL STANDING WATER, AND EXTENDED DRIER PERIODS.
- ZONE 3: AREA WITH DRIER CONDITIONS.

NOTES

1. MAXIMUM BOTTOM SLOPE OF CELL IS 0.5%.
2. OVERFLOW POINT SHALL BE AT LEAST 6" BELOW ANY ADJACENT PAVEMENT AREA.
3. MINIMUM 3' DEPTH BETWEEN UNDERDRAIN (IF PRESENT) OR BOTTOM OF BIORETENTION SOIL MIX (BSM) AND WATER TABLE.
4. INSTALL STREAMBED COBBLE (1" - 4") AT INLET TO DISSIPATE RUNOFF.
5. BSM SHALL CONTAIN THE FOLLOWING:
 - AGGREGATE TO COMPOST RATIO: 60% MINERAL AGGREGATE (WITH LESS THAN 5% FINES), 40% MAX COMPOST (MEET REQUIREMENTS IN WAC 173-350-220).
 - TOTAL BSM ORGANIC MATTER CONTENT OF 4-8% (BY DRY WEIGHT)
 - BSM DEPTH OF 12-24". ENHANCED TREATMENT REQUIRES MIN DEPTH OF 18".
6. MINIMUM SETBACK OF 5' FROM TOP OF BIORETENTION CELL TO BUILDING STRUCTURES AND PROPERTY LINES. DO NOT LOCATE IMMEDIATELY UPSLOPE OF BUILDING STRUCTURES.
7. MAX 3" MULCH LAYER IN PONDING AREA AND ON SIDES SLOPES. MULCH MUST BE ARBORIST OR HOG FUEL WITHOUT BARK, CONSISTING OF SHREDDED OR CHIPPED HARDWOOD. MULCH SHALL NOT CONTAIN WEED SEEDS, GRASS CLIPPINGS, OR BARK.
8. IF OPTIONAL UNDERDRAIN IS USED:
 - USE SLOTTED SUBSURFACE DRAIN PVC PER ASTM D1785 SCH 40, NOT PERFORATED PVC OR FLEXIBLE SLOTTED HDPE
 - 0.5% MIN SLOPE
 - PROVIDE A CLEAN OUT EVERY 250-300 FEET
9. FOR CELLS IN PARKING LOTS, ADD NARROW GRAVEL FOOT PATHS ACROSS CELLS FOR FOOT TRAFFIC.
10. 2' MIN BETWEEN WHEEL STOP AND EDGE OF ASPHALT, EXTEND FLAT SOIL 1' FROM EDGE OF ASPHALT BEFORE STARTING 3H:1V SLOPE.

CITY OF KIRKLAND

PLAN NO. CK - L.01



**BIORETENTION CELL
PIPED I/O**