


NOTES

1. REQUIRED FOR ANY PIPE 8" OR LARGER.
2. DEBRIS BARRIER MUST BE ALL ALUMINUM.
3. DEBRIS BARRIER NOT ALLOWED ON OUTLET END.
4. ALL BOLT HARDWARE SHALL BE STAINLESS STEEL.
5. ATWOOD FABRICATION OR APPROVED EQUAL.

| | |
|--|---|
| CITY OF KIRKLAND | |
| PLAN NO. CK - D.27A | |
|  | TYPICAL DEBRIS BARRIER WITH OVERFLOW |