



## NOTES:

1. CONTRACTOR TO VERIFY BOLT PATTERN WITH CABINETS.
2. CONTRACTOR SHALL PROVIDE A MINIMUM CLEARANCE OF 48 INCHES FROM FRONT FACE OF CABINETS TO ALLOW FOR DOOR SWING AND WORKING SPACE. CONTRACTOR SHALL HAVE A MINIMUM 4-FOOT OFFSET FROM ANY OBSTRUCTIONS SUCH AS A WALL TO ALLOW FOR FUTURE MAINTENANCE.
3. CONTRACTOR SHALL PROVIDE A MINIMUM OF FOUR (4) 3" CONDUITS AND ONE (1) 2" CONDUIT FROM SIGNAL CABINET INTO THE NEAREST JUNCTION BOX.
4. CONTRACTOR SHALL INSTALL TWO GROUND RODS AND CABINET GROUNDING PER WSDOT STANDARD PLANS J-10.10 AND J-60.05.
5. CONTRACTOR SHALL POUR FOUNDATION TO BE SMOOTH AND LEVEL TO ENSURE PROPER OPERATION OF CABINET. ALL CONCRETE CORNERS SHALL HAVE A 1" CHAMFER, UNLESS ABUTTING SIDEWALK, WHERE IT SHALL BE SQUARE AND SEPARATED FROM THE SIDEWALK WITH JOINT FILLER.
6. CABINET HOUSEKEEPING PAD SHALL BE MINIMUM DIMENSIONS SHOWN, FLAT, UNCONSTRAINED BY OTHER STRUCTURES, AND OUTSIDE OF LOW POINT AREAS WHERE STORMWATER COLLECTS. WELDED WIRE FABRIC IN PAD SHALL BE 4" X 4" MEETING THE REQUIREMENTS OF WSDOT STANDARD SPECIFICATION 7-07.1. AS AN ALTERNATIVE, A GRID OF #3 REBAR MAY BE USED, WITH BARS SPACED AT 12" CENTERS LATERALLY AND LONGITUDINALLY.
7. ALL REBAR SHALL BE DEFORMED STEEL REINFORCING BAR FOR CONCRETE FOUNDATIONS CONFORMING TO ASTM A615 GRADE 60.

