


NOTES:

1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE
 * 30" FOR PIPE UP TO AND INCLUDING 12" NOMINAL DIAMETER.
 * OD PLUS 16" FOR PIPE LARGER THAN 12" NOMINAL DIAMETER.
2. WHERE TRENCH IS PERPENDICULAR TO TRAVELED LANES, BACKFILL FULL DEPTH WITH CRUSHED SURFACING-TOP COURSE. WHERE TRENCH IS PARALLEL TO TRAVELED LANES, BACKFILL THE TOP 4' OF TRENCH TO SUBGRADE WITH CRUSHED SURFACING-TOP COURSE. SUITABLE EXCAVATED MATERIAL MAY BE USED PROVIDED 95% MAX. COMPACTION DENSITY (ASTM D1557) CAN BE ACHIEVED.
3. SEE OVERLAY POLICY R-7.
4. USE OF RECYCLED CONCRETE IS PROHIBITED, UNLESS APPROVED BY THE CITY. SEE POLICY D-16.

CITY OF KIRKLAND	
PLAN NO. CK - D.02	
	STORM TRENCH DETAIL