


NOT TO SCALE

NOTES

1. THE STANDARD PEDESTRIAN LIGHT ASSEMBLY CONSISTS OF THE FOLLOWING IN DARK FOREST GREEN COLOR (RAL6012 TEXTURED GN8TX):
 - APR4U-12-GFII-LBC2-PSS16-GN8TX 12-FOOT TALL ALUMINUM POLE WITH TWO-PIECE ROUND BASE COVER, AND SINGLE PLANT SUPPORT
 - 3/4"X24"X4" F1554 GRADE-55 DOMESTIC GALVANIZED ANCHOR BOLT KIT
 - CN1-1A-GN8TX MOUNTING BRACKET
 - LUMEC CANDELA PENDANT LED LUMINAIRE FIXTURE, 3000K COLOR TEMPERATURE, **CAND1-65W42LED3K-G2-PC-C-RLE5-UNV-GN8TX** OR APPROVED EQUAL
 - GFI DUPLEX RECEPTACLE, WEATHER RESISTANT, 120V, GROUND FAULT INTERRUPTER, WIRED WITH 15 AMP SEPARATE CIRCUIT, NEMA 15-15R
2. POLE ASSEMBLY COLOR MAY BE TEAL INSTEAD OF DARK FOREST GREEN DEPENDING ON SURROUNDING AREA, AS DIRECTED AND APPROVED BY PUBLIC WORKS.
3. POLE SPACING TO BE APPROXIMATELY 60 FEET ON CENTER AND/OR AS REQUIRED BY CITY OF KIRKLAND PUBLIC WORKS DEPARTMENT BASED ON LIGHTING ANALYSIS OR OTHER FACTORS. SEE PUBLIC WORKS PRE-APPROVED PLANS POLICY R-40 FOR LIGHTING DESIGN GUIDELINES.
4. PEDESTRIAN LIGHT POLES SHALL BE PLACED AT THE BACK OF THE SIDEWALK WHEREVER PRACTICAL. POLE PLACEMENT SHALL COMPLY WITH PUBLIC WORKS PRE-APPROVED PLAN CK-R.47B AND POLICY R-40.
5. ALL SPLICE CONNECTIONS IN J-BOX SHALL BE MADE USING:
 - A. C-TAP (COPPER CRIMP)
 - B. 3M 2000 MASTIC COVER
 - C. 3M SUPER 88 TAPE

CITY OF KIRKLAND	
PLAN NO. CK - R.47	
	CENTRAL BUSINESS DISTRICT PEDESTRIAN LIGHT STANDARD